

RE4040-BE



High productivity RO element with extended area for brackish water

SPECIFICATIONS:

General **Features** Permeate flow rate: 2,400 GPD (9.1 m³/day)

Nominal salt rejection: 99.7% Effective membrane area: 85 ft² (7.9 m²)

- 1. The stated product performance is based on data taken after 30 minutes of operation at the following test conditions:
 - 2,000 mg/L NaCl solution at 225 psig (1.55 MPa) applied pressure
- 15% recovery
- 77 ∘F (25 ∘C)
- pH 6.5-7.0
- 2. Minimum salt rejection is 99.4%.
- 3. Permeate flow rate for each element may vary +25 /-15%.
- 4. All elements are vacuum sealed in a polyethylene bag containing 1.0% SBS (sodium bisulfite) solution and individually packaged in a cardboard box.

Membrane type: Thin-Film Composite Membrane material: Polyamide (PA)

Spiral-Wound, FRPWrapping Element configuration:

Dimensions

Model Name	A	В	С	D/E	Part Number	
					Inter- connector	Brine Seal
RE4040-BE	40.0 inch (1,016 mm)	3.9 inch (99 mm)	0.75 inch (19 mm)	1.05 inch (26.7 mm)	SWA01050	SWA01046



- 1. Each membrane element supplied with one brine seal, one interconnector (coupler) and four o-rings. 2. All RE4040 elements fit nominal 4.0 inch (101.6 mm) I.D. pressure vessels.

The information provided in this document is solely for informative purposes. It is the user's responsibility to ensure the appropriate usage of this product. Toray Advanced Materials Korea Inc. assumes no obligation, liability or damages incurred for the misuse of the product or for the information provided in this document. This document does not express or implies any warranty as to the merchantability or fitness of the product.



RE4040-BE



High productivity RO element with extended area for brackish water

APPLICATION DATA:

Operating Limits	 Max. Pressure Drop / Element Max. Pressure Drop / 240" Vessel Max. Operating Pressure Max. Feed Flow Rate Min. Concentrate Flow Rate Max. Operating Temperature Operating pH Range CIP pH Range Max. Turbidity Max. SDI (15 min) Max. Chlorine Concentration 	15 psi (0.1 MPa) 60 psi (0.41 Mpa) 600 psi (4.14 MPa) 18 gpm (4.09 m³/hr) 4 gpm (0.91 m³/hr) 113 °F (45 °C) 2.0–11.0 1.0–13.0 1.0 NTU 5.0 < 0.05 mg/L
Design Guidelines for Various Water Sources	 Wastewater Conventional (SDI < 5) Wastewater Pretreated by UF/MF (SDI < 3) Seawater, Open Intake (SDI < 5) Seawater, Beach Well (SDI < 3) Surface Water (SDI < 5) Surface Water (SDI < 3) Well water (SDI < 3) RO permeate (SDI < 1) 	8–12 gfd 10–14 gfd 7–10 gfd 8–12 gfd 12–16 gfd 13–17 gfd 13–17 gfd 21–30 gfd
Saturation Limits (Using Antiscalants) [†]	Langlier Saturation Index (LSI) Stiff and Davis Saturation Index (SDSI) CaSO4 SrSO4 BaSO4 SiO2 The above saturation limits are typically accepted by manufacturers. It is the user's responsibility to ensure concentration are dosed ahead of the membrane system. Mor damaged due to scale formation are not covered.	e proper chemical(s) and stem to prevent scale lembrane elements fouled

GENERAL HANDLING PROCEDURES

- Elements contained in the boxes must be kept dry at room temperature (7–32°C; 40–95°F) and should not be stored in direct sunlight. If the polyethylene bag is damaged, a new preservative solution (sodium bisulfite) must be added and air-tight sealed to prevent drying and biological growth.
- Permeate from the first hour of operation should be discarded to flush out the preservative solution.
- Elements should be immersed in a preservative solution during storage, shipping and system shutdowns to prevent biological growth and freezing. The standard storage solution contains 1% by weight sodium bisulfite or sodium metabisulfite (food grade). For short term storage (i.e. one week or less) 1% by weight sodium metabisulfite solution is adequate for preventing biological growth.
- Keep elements moist at all times after initial wetting.
- Avoid excessive pressure and flow spikes.
- Only use chemicals compatible with the membrane elements and components. Use of such chemicals may void the element limited warranty.
- Permeate pressure must always be equal or less than the feed/concentrate pressure. Damage caused by permeate back pressure voids the element limited warranty.



www.productospolo.com



RE4040-BLN



Low pressure grade RO element for brackish water

SPECIFICATIONS:

General Features Permeate flow rate: 2,600 GPD (9.8 m³/day)

Nominal salt rejection: 99.4% Effective membrane area: 85 ft² (7.9 m²)


- 1. The stated product performance is based on data taken after 30 minutes of operation at the following test conditions:
 - 1,500 mg/L NaCl solution at 150 psig (1.03 MPa) applied pressure
 - I5% recovery
 - 77 ∘F (25 ∘C)
 - pH 6.5-7.0
- 2. Minimum salt rejection is 99.3%.
- 3. Permeate flow rate for each element may vary +25 /-15%.
- All elements are vacuum sealed in a polyethylene bag containing 1.0% SBS (sodium bisulfite) solution and individually packaged in a cardboard box.

Membrane type:Thin-Film CompositeMembrane material:Polyamide (PA)

Element configuration: Spiral-Wound, FRPWrapping

Dimensions

Model Name	A	В	С	D/E	Part Number	
					Inter- connector	Brine Seal
RE4040-BLN	40.0 inch (1,016 mm)	3.9 inch (99 mm)	0.75 inch (19 mm)	1.05 inch (26.7 mm)	SWA01050	SWA01046



- 1. Each membrane element supplied with one brine seal, one interconnector (coupler) and four o-rings.
- 2. All RE4040 elements fit nominal 4.0 inch (101.6 mm) I.D. pressure vessels.

www.productospolo.com

The information provided in this document is solely for informative purposes. It is the user's responsibility to ensure the appropriate usage of this product. Toray Advanced Materials Korea Inc. assumes no obligation, liability or damages incurred for the misuse of the product or for the information provided in this document. This document does not express or implies any warranty as to the merchantability or fitness of the product.



RE4040-BLN



Low pressure grade RO element for brackish water

APPLICATION DATA:

Operating Limits	 Max. Pressure Drop / Element Max. Pressure Drop / 240" Vessel Max. Operating Pressure Max. Feed Flow Rate Min. Concentrate Flow Rate Max. Operating Temperature Operating pH Range CIP pH Range Max. Turbidity Max. SDI (15 min) Max. Chlorine Concentration 	15 psi (0.1 MPa) 60 psi (0.41 Mpa) 600 psi (4.14 MPa) 18 gpm (4.09 m³/hr) 4 gpm (0.91 m³/hr) 113 °F (45 °C) 2.0–11.0 1.0–13.0 1.0 NTU 5.0 < 0.05 mg/L
Design Guidelines for Various Water Sources	Wastewater Conventional (SDI < 5) Wastewater Pretreated by UF/MF (SDI < 3) Seawater, Open Intake (SDI < 5) Seawater, Beach Well (SDI < 3) Surface Water (SDI < 5) Surface Water (SDI < 3) Well water (SDI < 3) RO permeate (SDI < 1)	8–12 gfd 10–14 gfd 7–10 gfd 8–12 gfd 12–16 gfd 13–17 gfd 13–17 gfd 21–30 gfd
Saturation Limits (Using Antiscalants) [†]	Langlier Saturation Index (LSI) Stiff and Davis Saturation Index (SDSI) CaSO4 SrSO4 BaSO4 SiO2 The above saturation limits are typically accepted by manufacturers. It is the user's responsibility to ensure concentration are dosed ahead of the membrane system. Mor damaged due to scale formation are not covered.	e proper chemical(s) and stem to prevent scale lembrane elements fouled

GENERAL HANDLING PROCEDURES

- Elements contained in the boxes must be kept dry at room temperature (7–32°C; 40–95°F) and should not be stored in direct sunlight. If the polyethylene bag is damaged, a new preservative solution (sodium bisulfite) must be added and air-tight sealed to prevent drying and biological growth.
- Permeate from the first hour of operation should be discarded to flush out the preservative solution.
- Elements should be immersed in a preservative solution during storage, shipping and system shutdowns to prevent biological growth and freezing. The standard storage solution contains 1% by weight sodium bisulfite or sodium metabisulfite (food grade). For short term storage (i.e. one week or less) 1% by weight sodium metabisulfite solution is adequate for preventing biological growth.
- Keep elements moist at all times after initial wetting.
- · Avoid excessive pressure and flow spikes.
- Only use chemicals compatible with the membrane elements and components. Use of such chemicals may void the element limited warranty.
- Permeate pressure must always be equal or less than the feed/concentrate pressure. Damage caused by permeate back pressure voids the element limited warranty.



www.productospolo.com